



By Royal Charter

Certificate of Constancy of Performance

This is to certify that:

Ningbo Hi-Tech Park Jabo
Electronics Co Ltd
Building 6
No. 799 Lingyun Road
Ningbo Hi-Tech Park
Ningbo
315103
China

Holds Certificate Number:

0086-CPR-550646

In respect of:

EN 14604: 2005
Smoke alarm devices.

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the above construction product. This certificate attests that all the provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the above standard(s) under system 1 are applied and that the product fulfils (products fulfil) all the prescribed requirements set out above. This certificate remains valid as long as the test methods and/or factory production control requirements included in the harmonised standard(s), used to assess the performance of the declared essential characteristics, do not change and the products(s), and the manufacturing conditions in the plants(s) are not modified significantly.

For and on behalf of BSI, a Notified Body for the above Regulation (Notified Body Number 0086):

Gary Fenton, Global Product Certification Director

First Issued: 2010-04-26

Latest Issue: 2017-05-03

Page: 1 of 5

...making excellence a habit.™

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request. To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK. A member of BSI Group of Companies.

Certificate of Constancy of Performance

No. 0086-CPR-550646

Manufacturing Plant:

Ningbo Hi-Tech Park Jabo Electronics Co. Ltd
Building 6, No. 799 Lingyun Road
Ningbo Hi-Tech Park
Ningbo
315103
China

Product Information

Battery Powered Smoke Alarms

Model Reference	Type
JB-S01	Photoelectric Smoke Alarm
JB-S02	Photoelectric Smoke Alarm
JB-S03	Photoelectric Smoke Alarm
JB-S07	Photoelectric Smoke Alarm
JB-S09	Photoelectric Smoke Alarm with Alarm Silence Function

Model Reference	Alternative Branded Model	Supplier
JB-S01	D-TECTRON DT-S01 LOREX LR-SAS	SHANGHAI HUIYING INDUSTRY CO., LTD FURKAN MUHENDİSLİK ELK.TURZ.İNŞ.TEKST.SAN.TİC.LTD.ŞTİ.
JB-S02	CMI 345682 CMI 345683 Fire Hawk FHB1 DA-01 DSD100 520009 520010	Emil Lux GmbH & Co. KG Emil Lux GmbH & Co. KG Fireblitz Extinguisher Limited Kent Fire Global Limited Lexibook S.A. OTIO SAS (subsidiary of HBF Group) OTIO SAS (subsidiary of HBF Group)

First Issued: 2010-04-26

Latest Issue: 2017-05-03

Page: 2 of 5

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.

Certificate of Constancy of Performance

No. 0086-CPR-550646

Model Reference	Alternative Branded Model	Supplier
JB-S02	SEDEA 598001	SEDEA Electronique
	SS-01b1	SEESAFE Diffusion
	SS-01b5	SEESAFE Diffusion
	SS-01b10	SEESAFE Diffusion
	Carrera RM-01	Silag Handel AG
	W-SAVE WS1	Weckx Handelssonderneming
JB-S03	D-TECTRON DT-S02	SHANGHAI HUIYING INDUSTRY CO., LTD
	SD\1B	Spółdzielnia Inwalidów SPAMEL
JB-S03	D-TECTRON DT-S03	SHANGHAI HUIYING INDUSTRY CO., LTD
JB-S07	RM-200	M-E GMBH MODERN-ELECTRONICS
	RM-210	M-E GMBH MODERN-ELECTRONICS
JB-S09	RM 10 mini	OLYMPIA Business Systems Vertriebs GmbH
	1085027	Flow Trading B.V.

First Issued: 2010-04-26

Latest Issue: 2017-05-03

Page: 3 of 5

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.

Certificate of Constasy of Performance

No. 0086-CPR-550646

Appendix 1

Harmonised Technical Specification		EN 14604:2005
Essential Characteristics	Performance	Clause
Nominal activation conditions / sensitivity / response delay (response time) and performance under fire conditions		
Smoke alarm signals	Pass	4.12
Repeatability	Pass	5.2
Directional dependence	Pass	5.3
Initial sensitivity	Pass	5.4
Air movement	Pass	5.5
Dazzling	Pass	5.6
Fire sensitivity	Pass	5.15
Sound output	Pass	5.17
Sounder durability	Pass	5.18
Alarm silence facility	Pass	5.20
Operational Reliability		
Compliance	Pass	4.1
Individual alarm indicator	Pass	4.2
Means of calibration	Pass	4.5
User replaceable components	Pass	4.6
Normal power source	Pass	4.7
Electrical safety requirements	Pass	4.9, 5.24
Routine test facility	Pass	4.10
Battery removal indication	Pass	4.13
Battery connections	Pass	4.14
Battery capacity	Pass	4.15
Protection against the ingress of foreign bodies	Pass	4.16
Marking and data	Pass	4.19

First Issued: 2010-04-26

Latest Issue: 2017-05-03

Page: 4 of 5

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.

Certificate of Constancy of Performance

No. 0086-CPR-550646

Appendix 1 (continued)

Harmonised Technical Specification		EN 14604:2005
Essential Characteristics	Performance	Clause
Operational Reliability		
Impact	Pass	5.11
Battery fault warning	Pass	5.16
Battery reversal	Pass	5.22
Tolerance to supply voltage		
Variation in supply voltage	Pass	5.21
Durability of Operational Reliability		
Dry heat	Pass	5.7
Cold (operational)	Pass	5.8
Damp heat (operational)	Pass	5.9
Sulphur dioxide (SO ₂) corrosion	Pass	5.10
Vibration (operational)	Pass	5.12
Vibration (endurance)	Pass	5.13
Durability of Operational Reliability, Electrical Stability		
Electromagnetic compatibility (EMC), immunity (operational)	Pass	5.14

First Issued: 2010-04-26

Latest Issue: 2017-05-03

Page: 5 of 5

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.